

施設排ガス測定データ

2021年 4月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)							
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均			
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号		
1	木	3		1		2		7		2		5		29		1		19		0.00		0.00		0.00		30		15		23		
2	金	2		1		1		6		1		3		31		0		14		0.00		0.00		0.00		34		16		23		
3	土	3		1		2		6		1		3		29		0		15		0.00		0.00		0.00		30		15		22		
4	日	6		1		2		8		1		3		31		0		13		0.00		0.00		0.00		34		18		23		
5	月	3		1		1		8		0		3		36		1		18		0.00		0.00		0.00		31		15		22		
6	火	2		1		1		6		1		4		30		1		13		0.00		0.00		0.00		29		18		23		
7	水	6		1		2		7		1		4		30		3		16		0.00		0.00		0.00		36		19		23		
8	木	2	立上げ	1	立上げ	1	立上げ	7	立上げ	1	立上げ	4	立上げ	31	立上げ	4	立上げ	17	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	26	立上げ	13	立上げ	21	立上げ	
9	金	2	2	1	2	1	2	7	7	3	3	5	6	26	29	20	8	24	19	0.00	0.00	0.00	0.00	0.00	0.00	26	30	17	7	22	19	
10	土		2		1		2		7		1		5		30		4		22		0.00		0.00		0.00		29		11		20	
11	日		2		1		2		9		1		6		21		10		18		0.00		0.00		0.00		34		7		19	
12	月		2		1		2		7		3		6		27		15		23		0.00		0.00		0.00		33		9		19	
13	火		2		1		1		7		2		6		30		13		23		0.00		0.00		0.00		33		8		20	
14	水		2		1		1		7		4		6		30		18		22		0.00		0.00		0.00		30		12		20	
15	木		2		1		1		9		4		6		29		16		24		0.00		0.00		0.00		30		8		19	
16	金		2		1		1		8		3		6		33		10		26		0.00		0.00		0.00		33		8		18	
17	土		2		1		1		7		4		6		35		19		27		0.00		0.00		0.00		31		8		20	
18	日		4		1		1		8		4		6		32		20		27		0.00		0.00		0.00		30		8		20	
19	月		2		1		1		8		5		6		33		14		27		0.00		0.00		0.00		34		13		21	
20	火		3		1		1		7		3		5		33		18		25		0.00		0.00		0.00		32		11		21	
21	水		2		1		1		6		1		5		34		15		28		0.00		0.00		0.00		33		13		21	
22	木		2		1		2		6		2		4		34		8		24		0.00		0.00		0.00		31		8		20	
23	金		2		1		1		8		4		6		33		14		25		0.00		0.00		0.00		32		8		19	
24	土		3		1		2		8		4		6		32		23		27		0.00		0.00		0.00		31		11		20	
25	日		5		1		2		8		2		5		31		11		25		0.00		0.00		0.00		34		10		21	
26	月		2		1		1		8		2		6		31		5		24		0.00		0.00		0.00		30		13		21	
27	火	立上げ	2	立上げ	1	立上げ	2	立上げ	7	立上げ	3	立上げ	5	立上げ	29	立上げ	11	立上げ	19	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	32	立上げ	10	立上げ	21	
28	水	2	2	1	1	1	1	4	7	1	2	2	5	28	28	2	11	12	21	0.00	0.00	0.00	0.00	0.00	0.00	28	31	16	9	23	20	
29	木	1	2	1	1	1	1	8	7	1	4	4	6	33	25	3	13	15	17	0.00	0.00	0.00	0.00	0.00	0.00	26	31	13	9	21	19	
30	金	1	2	0	1	1	1	7	8	0	2	3	6	31	30	3	14	17	24	0.00	0.00	0.00	0.00	0.00	0.00	32	30	7	7	19	19	
31																																
最大		6	5	1	2	2	2	8	9	3	5	5	6	36	35	20	23	24	28	0.00	0.00	0.00	0.00	0.00	0.00	36	34	19	13	23	21	
最小		1	2	0	1	1	1	4	6	0	1	2	4	26	21	0	4	12	17	0.00	0.00	0.00	0.00	0.00	0.00	26	29	7	7	19	18	
平均		3	2	1	1	1	1	7	7	1	3	4	6	30	30	3	13	16	24	0.00	0.00	0.00	0.00	0.00	0.00	30	32	15	9	22	20	
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm						
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm						
※ 備考	運転管理に基づき 2号炉 4月8日立上げ 1号炉 4月9日立下げ 1号炉 4月27日立上げ 休炉																															