

施設排ガス測定データ

2022年 3月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	火	1	2	0	1	0	1	5	3	1	1	3	2	18	12	2	5	9	8	0.00	0.00	0.00	0.00	0.00	0.00	33	25	16	7	22	15
2	水	1	2	0	1	1	1	3	5	1	2	2	3	23	16	0	7	8	10	0.00	0.00	0.00	0.00	0.00	0.00	31	29	16	9	22	19
3	木	1	2	0	1	1	1	6	6	1	2	4	3	28	30	0	10	16	16	0.00	0.00	0.00	0.00	0.00	0.00	35	26	17	9	23	18
4	金	1	2	0	1	0	1	1	5	0	1	1	2	2	15	0	3	0	8	0.00	0.00	0.00	0.00	0.00	0.00	23	25	13	11	17	17
5	土	1	8	0	1	1	2	1	5	0	1	1	3	25	16	0	6	7	10	0.00	0.00	0.00	0.00	0.00	0.00	32	28	13	11	21	19
6	日	1	2	0	1	1	1	1	7	0	1	0	4	16	33	0	4	4	14	0.00	0.00	0.00	0.00	0.00	0.00	28	27	12	5	17	15
7	月	1	2	0	1	1	1	1	6	0	1	0	2	2	25	0	4	0	14	0.00	0.00	0.00	0.00	0.00	0.00	24	29	14	5	18	13
8	火	1	2	0	1	1	1	1	7	0	1	0	3	2	28	0	1	0	13	0.00	0.00	0.00	0.00	0.00	0.00	29	27	12	4	20	15
9	水	1	4	0	1	0	1	1	7	0	1	1	4	18	24	0	6	3	14	0.00	0.00	0.00	0.00	0.00	0.00	21	28	11	5	17	16
10	木	1	2	0	1	1	2	2	5	0	2	1	3	14	28	0	7	3	15	0.00	0.00	0.00	0.00	0.00	0.00	27	34	15	6	19	17
11	金	1	2	0	1	0	1	1	6	1	1	1	3	6	20	0	7	1	13	0.00	0.00	0.00	0.00	0.00	0.00	31	35	16	9	20	19
12	土	1	2	0	1	0	2	1	7	1	1	1	5	30	27	0	8	11	17	0.00	0.00	0.00	0.00	0.00	0.00	30	31	15	6	21	18
13	日	1	2	0	1	1	2	5	7	1	3	3	5	29	27	0	13	19	21	0.00	0.00	0.00	0.00	0.00	0.00	37	33	14	8	23	19
14	月	1	2	0	1	1	2	3	7	1	1	1	4	26	26	0	6	9	17	0.00	0.00	0.00	0.00	0.00	0.00	35	33	15	3	24	17
15	火	1	2	0	1	1	2	1	7	0	1	1	4	28	24	0	8	8	14	0.00	0.00	0.00	0.00	0.00	0.00	32	36	10	4	22	12
16	水	1	立下げ	0	立下げ	1	立下げ	1	立下げ	0	立下げ	1	立下げ	29	立下げ	0	立下げ	4	立下げ	0.00	立下げ	0.00	立下げ	0.00	立下げ	36	立下げ	18	立下げ	29	立下げ
17	木	1		0		1		1		0		0		20		0		4		0.00		0.00		0.00		38		20		28	
18	金	1		0		0		1		0		1		24		0		6		0.00		0.00		0.00		35		20		27	
19	土	1		0		1		1		0		1		25		0		9		0.00		0.00		0.00		33		21		26	
20	日	1		0		0		1		0		0		26		0		4		0.00		0.00		0.00		38		16		29	
21	月	1		0		1		1		0		0		30		0		10		0.00		0.00		0.00		39		17		26	
22	火	1		0		1		1		0		1		24		0		10		0.00		0.00		0.00		35		16		26	
23	水	1		0		1		1		0		0		25		0		4		0.00		0.00		0.00		39		18		27	
24	木	1		0		0		1		0		0		28		0		6		0.00		0.00		0.00		36		13		26	
25	金	6		0		1		1		0		0		23		0		3		0.00		0.00		0.00		36		15		27	
26	土	1		0		1		1		0		1		1		0		0		0.00		0.00		0.00		35		23		29	
27	日	1		0		1		1		0		0		28		0		10		0.00		0.00		0.00		34		19		25	
28	月	1		0		0		1		0		0		32		0		3		0.00		0.00		0.00		33		17		25	
29	火	1		0		0		1		0		0		21		0		5		0.00		0.00		0.00		33		21		26	
30	水	3		1		1		1		0		1		28		0		7		0.00		0.00		0.00		44		17		25	
31	木	3		0		1		1		0		0		30		0		15		0.00		0.00		0.00		32		18		25	
最大		6	8	1	1	1	2	6	7	1	3	4	5	32	33	2	13	19	21	0.00	0.00	0.00	0.00	0.00	0.00	44	36	23	11	29	19
最小		1	2	0	1	0	1	1	3	0	1	0	2	1	12	0	1	0	8	0.00	0.00	0.00	0.00	0.00	0.00	21	25	10	3	17	12
平均		1	3	0	1	1	1	2	6	0	1	1	3	21	23	0	6	6	14	0.00	0.00	0.00	0.00	0.00	0.00	33	30	16	7	24	17
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考	運転管理に基づき 2号炉 3月16日立下げ 休炉																														