

施設排ガス測定データ

2024年 2月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	木	1	2	1	2	1	2	6	6	1	2	3	4	22	29	6	11	13	20	0.00	0.00	0.00	0.00	0.00	0.00	37	36	32	33	35	34
2	金	1	2	1	1	1	1	2	4	1	1	1	3	22	28	7	12	14	19	0.00	0.00	0.00	0.00	0.00	0.00	37	36	32	32	35	35
3	土	1	2	1	1	1	2	3	4	0	1	1	3	23	30	5	12	15	24	0.00	0.00	0.00	0.00	0.00	0.00	36	36	33	32	35	34
4	日	1	2	1	1	1	1	5	6	1	2	3	4	25	27	5	9	14	20	0.00	0.00	0.00	0.00	0.00	0.00	36	37	32	27	34	34
5	月	1	2	1	1	1	2	2	6	0	1	1	3	16	28	2	5	8	17	0.00	0.00	0.00	0.00	0.00	0.00	37	37	23	24	33	33
6	火	1	2	1	1	1	1	2	3	0	1	1	2	13	14	2	3	7	9	0.00	0.00	0.00	0.00	0.00	0.00	36	36	26	30	34	34
7	水	1	2	1	1	1	2	3	4	1	1	1	2	11	14	3	5	7	7	0.00	0.00	0.00	0.00	0.00	0.00	41	35	27	28	33	32
8	木	1	2	0	1	1	2	4	6	1	2	2	3	13	16	5	5	8	10	0.00	0.00	0.00	0.00	0.00	0.00	37	36	28	27	33	32
9	金	1	2	1	1	1	2	5	6	1	1	3	4	29	27	10	5	20	15	0.00	0.00	0.00	0.00	0.00	0.00	37	37	31	27	34	34
10	土	1	2	1	1	1	2	4	6	1	1	2	3	27	24	6	5	14	12	0.00	0.00	0.00	0.00	0.00	0.00	37	36	31	27	35	34
11	日	1	2	0	1	1	1	4	4	1	2	2	3	20	21	2	9	9	13	0.00	0.00	0.00	0.00	0.00	0.00	37	37	23	31	34	35
12	月	1	2	1	1	1	2	3	5	1	1	1	3	18	22	5	6	10	14	0.00	0.00	0.00	0.00	0.00	0.00	37	36	27	30	33	33
13	火	1	2	0	1	1	2	5	7	1	2	2	4	24	27	5	8	13	16	0.00	0.00	0.00	0.00	0.00	0.00	37	36	28	28	34	34
14	水	1	2	1	1	1	2	3	6	1	1	1	3	13	21	5	6	8	14	0.00	0.00	0.00	0.00	0.00	0.00	37	36	31	30	34	34
15	木	1	2	1	1	1	2	3	6	1	1	2	2	21	22	1	2	8	9	0.00	0.00	0.00	0.00	0.00	0.00	37	37	28	27	33	33
16	金	1	2	0	1	1	1	4	5	1	1	2	3	20	25	6	6	14	16	0.00	0.00	0.00	0.00	0.00	0.00	37	36	26	28	33	33
17	土	1	2	0	1	1	1	5	5	1	1	2	3	25	28	5	8	14	16	0.00	0.00	0.00	0.00	0.00	0.00	36	37	12	26	32	34
18	日	1	2	1	2	1	2	4	5	1	2	2	3	24	28	9	12	18	18	0.00	0.00	0.00	0.00	0.00	0.00	37	37	25	21	34	34
19	月	1	2	1	1	1	2	5	6	1	2	3	4	24	23	5	3	14	13	0.00	0.00	0.00	0.00	0.00	0.00	36	38	28	15	33	30
20	火	1	2	1	2	1	2	4	4	1	2	2	3	20	21	4	5	11	11	0.00	0.00	0.00	0.00	0.00	0.00	37	37	27	27	33	34
21	水	1	2	1	1	1	2	4	4	1	2	2	3	19	20	7	5	13	11	0.00	0.00	0.00	0.00	0.00	0.00	36	36	29	27	34	33
22	木	1	3	1	1	1	2	4	6	1	2	2	4	24	24	8	7	15	18	0.00	0.00	0.00	0.00	0.00	0.00	36	36	24	30	32	34
23	金	1	1	0	1	1	1	5	6	1	1	2	4	31	29	9	9	18	21	0.00	0.00	0.00	0.00	0.00	0.00	37	37	24	30	33	34
24	土	0	1	0	1	0	1	5	5	1	2	3	4	29	29	17	16	24	24	0.00	0.00	0.00	0.00	0.00	0.00	37	36	26	26	34	33
25	日	1	1	0	1	0	1	6	12	1	2	4	5	32	29	20	8	27	22	0.00	0.00	0.00	0.00	0.00	0.00	38	36	26	28	34	33
26	月	1	1	0	1	0	1	3	5	1	1	2	3	26	26	7	7	16	17	0.00	0.00	0.00	0.00	0.00	0.00	38	37	23	28	33	34
27	火	0	1	0	1	0	1	3	4	1	1	2	2	22	20	4	6	12	14	0.00	0.00	0.00	0.00	0.00	0.00	38	36	24	28	33	33
28	水	0	1	0	1	0	1	3	6	1	2	2	4	31	34	11	11	20	21	0.00	0.00	0.00	0.00	0.00	0.00	36	38	28	29	34	34
29	木	0	1	0	1	0	1	4	9	1	2	2	3	28	28	7	11	17	18	0.00	0.00	0.00	0.00	0.00	0.00	36	35	23	19	32	31
最大		1	3	1	2	1	2	6	12	1	2	4	5	32	34	20	16	27	24	0.00	0.00	0.00	0.00	0.00	0.00	41	38	33	33	35	35
最小		0	1	0	1	0	1	2	3	0	1	1	2	11	14	1	2	7	7	0.00	0.00	0.00	0.00	0.00	0.00	36	35	12	15	32	30
平均		1	2	1	1	1	2	4	6	1	1	2	3	22	25	6	7	14	16	0.00	0.00	0.00	0.00	0.00	0.00	37	36	27	27	34	33
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.08 g/m ³ N						250 ppm					
※ 備考		休炉																													