

施設排ガス測定データ

2023年 2月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	水	1	1	0	1	1	1	7	8	1	2	3	4	31	27	10	11	20	18	0.00	0.00	0.00	0.00	0.00	0.00	31	32	27	27	29	29
2	木	1	1	0	1	1	1	4	5	1	1	3	3	26	26	8	11	17	17	0.00	0.00	0.00	0.00	0.00	0.00	32	32	23	25	28	30
3	金	1	1	0	1	1	1	5	6	1	1	3	3	27	24	12	9	20	17	0.00	0.00	0.00	0.00	0.00	0.00	33	31	23	29	29	30
4	土	1	1	0	1	1	1	6	6	2	3	4	4	32	32	16	13	25	19	0.00	0.00	0.00	0.00	0.00	0.00	32	32	27	28	30	30
5	日	1	2	0	1	1	1	5	7	3	4	4	5	34	29	24	19	28	25	0.00	0.00	0.00	0.00	0.00	0.00	32	32	28	28	30	30
6	月	1	2	0	1	1	1	3	6	0	1	1	3	29	29	2	6	15	17	0.00	0.00	0.00	0.00	0.00	0.00	31	32	25	23	28	29
7	火		1		1		1		7		3		5		29		13		17		0.00		0.00		0.00		38		27		30
8	水		2		1		1		7		3		5		25		11		17		0.00		0.00		0.00		33		24		29
9	木		2		1		2		7		3		5		31		14		21		0.00		0.00		0.00		31		24		29
10	金		2		1		2		7		4		6		29		11		22		0.00		0.00		0.00		33		27		30
11	土		2		1		2		6		4		5		31		22		27		0.00		0.00		0.00		32		29		30
12	日		2		2		2		7		3		6		33		9		24		0.00		0.00		0.00		32		25		30
13	月		2		2		2		7		4		6		26		14		18		0.00		0.00		0.00		31		28		30
14	火		9		2		2		7		3		5		26		12		19		0.00		0.00		0.00		31		27		30
15	水		2		1		2		5		2		4		25		12		18		0.00		0.00		0.00		33		28		30
16	木		2		1		2		7		2		5		27		8		21		0.00		0.00		0.00		31		27		30
17	金		2		2		2		7		2		4		30		15		22		0.00		0.00		0.00		32		28		30
18	土		2		2		2		6		2		4		29		11		20		0.00		0.00		0.00		33		26		30
19	日		2		2		2		7		3		5		26		11		17		0.00		0.00		0.00		33		28		30
20	月		2		2		2		7		1		4		26		8		17		0.00		0.00		0.00		31		27		30
21	火		3		2		2		6		1		4		28		9		19		0.00		0.00		0.00		32		27		30
22	水		2		2		2		6		3		5		31		17		24		0.00		0.00		0.00		32		27		30
23	木		2		2		2		6		3		4		33		11		21		0.00		0.00		0.00		31		28		30
24	金		2		2		2		5		2		4		26		12		20		0.00		0.00		0.00		32		28		30
25	土		2		2		2		6		2		4		28		11		21		0.00		0.00		0.00		32		28		30
26	日		2		2		2		7		3		4		30		16		22		0.00		0.00		0.00		31		28		30
27	月		3		2		2		6		3		4		27		12		19		0.00		0.00		0.00		32		26		30
28	火		2		2		2		7		3		5		26		12		17		0.00		0.00		0.00		31		28		30
最大		1	9	0	2	1	2	7	8	3	4	4	6	34	33	24	22	28	27	0.00	0.00	0.00	0.00	0.00	0.00	33	38	28	29	30	30
最小		1	1	0	1	1	1	3	5	0	1	1	3	26	24	2	6	15	17	0.00	0.00	0.00	0.00	0.00	0.00	31	31	23	23	28	29
平均		1	2	0	2	1	2	5	6	1	3	3	4	30	28	12	12	21	20	0.00	0.00	0.00	0.00	0.00	0.00	32	32	26	27	29	30
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考	設備保全に伴い 1号炉 2月6日立下げ 休炉																														