

施設排ガス測定データ

2021年 10月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)								
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均				
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号					
1	金	立上げ	3	立上げ	1	立上げ	2	立上げ	7	立上げ	1	立上げ	5	立上げ	30	立上げ	11	立上げ	23	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	32	立上げ	8	立上げ	20
2	土	2	2	1	1	2	2	2	5	0	2	1	4	5	33	0	18	2	26	0.00	0.00	0.00	0.00	0.00	0.00	28	31	12	7	20	19		
3	日	2	2	1	1	2	2	7	7	0	1	4	5	15	31	2	11	9	26	0.00	0.00	0.00	0.00	0.00	0.00	33	33	15	6	22	18		
4	月	2	7	1	1	1	2	6	6	0	3	4	4	24	33	1	21	12	28	0.00	0.00	0.00	0.00	0.00	0.00	31	32	11	11	20	20		
5	火	2	2	1	1	1	1	7	5	1	1	4	4	25	32	1	15	12	27	0.00	0.00	0.00	0.00	0.00	0.00	33	33	11	8	20	19		
6	水	2	2	1	1	1	2	8	7	1	1	5	5	25	31	0	15	15	25	0.00	0.00	0.00	0.00	0.00	0.00	32	35	10	6	19	16		
7	木	3	2	1	1	1	1	7	6	1	2	4	4	23	31	0	17	14	26	0.00	0.00	0.00	0.00	0.00	0.00	33	32	6	7	20	18		
8	金	2	2	1	1	1	2	7	10	0	1	3	4	25	31	0	12	12	23	0.00	0.00	0.00	0.00	0.00	0.00	32	35	10	7	18	17		
9	土	1	2	1	1	1	2	7	7	0	2	3	5	19	32	0	11	9	24	0.00	0.00	0.00	0.00	0.00	0.00	30	31	10	7	19	16		
10	日	4	2	1	1	1	2	6	6	1	2	4	4	26	33	1	21	13	28	0.00	0.00	0.00	0.00	0.00	0.00	30	32	11	9	20	19		
11	月	5	2	1	1	1	2	7	5	0	2	3	4	18	31	0	14	10	25	0.00	0.00	0.00	0.00	0.00	0.00	32	29	12	11	22	19		
12	火	1		1		1		7		0		2		22		0		8		0.00		0.00		0.00		33		9		20			
13	水	1		1		1		8		0		2		21		0		7		0.00		0.00		0.00		36		14		23			
14	木	1		1		1		7		0		3		29		0		13		0.00		0.00		0.00		32		13		22			
15	金	3		1		1		4		0		1		24		0		11		0.00		0.00		0.00		32		14		22			
16	土	3		0		1		7		1		4		20		0		9		0.00		0.00		0.00		32		15		22			
17	日	1		0		1		6		0		3		26		0		10		0.00		0.00		0.00		34		15		22			
18	月	5		1		1		8		0		4		24		1		12		0.00		0.00		0.00		31		14		22			
19	火	1		1		1		4		0		1		25		0		10		0.00		0.00		0.00		33		16		23			
20	水	1		0		1		6		0		2		21		0		9		0.00		0.00		0.00		36		15		23			
21	木	1		1		1		7		0		3		26		0		13		0.00		0.00		0.00		31		14		21			
22	金	1		1		1		6		0		2		28		0		11		0.00		0.00		0.00		33		18		24			
23	土	1		1		1		1		0		0		23		0		11		0.00		0.00		0.00		30		14		22			
24	日	1		0		1		6		0		3		27		0		11		0.00		0.00		0.00		38		11		22			
25	月	2		1		1		7		1		4		25		1		11		0.00		0.00		0.00		32		18		23			
26	火	2		1		1		11		0		2		18		0		7		0.00		0.00		0.00		31		15		22			
27	水	1		0		1		0		0		0		29		0		2		0.00		0.00		0.00		38		16		24			
28	木	1	立上げ	0	立上げ	1	立上げ	0	立上げ	0	立上げ	0	立上げ	26	立上げ	1	立上げ	12	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	35	立上げ	14	立上げ	23	立上げ		
29	金	1	2	0	2	1	2	4	7	0	0	1	4	23	2	1	0	13	1	0.00	0.00	0.00	0.00	0.00	0.00	33	34	15	4	22	15		
30	土	1	3	0	2	1	2	5	5	1	2	2	3	16	6	1	0	9	3	0.00	0.00	0.00	0.00	0.00	0.00	33	29	12	11	22	19		
31	日	2	2	1	2	1	2	5	6	1	1	2	3	17	7	1	1	8	3	0.00	0.00	0.00	0.00	0.00	0.00	33	31	15	6	22	17		
最大		5	7	1	2	2	2	11	10	1	3	5	5	29	33	2	21	15	28	0.00	0.00	0.00	0.00	0.00	0.00	38	35	18	11	24	20		
最小		1	2	0	1	1	1	0	5	0	0	0	3	5	2	0	0	2	1	0.00	0.00	0.00	0.00	0.00	0.00	28	29	6	4	18	15		
平均		2	3	1	1	1	2	6	6	0	2	3	4	23	26	0	12	10	21	0.00	0.00	0.00	0.00	0.00	0.00	33	32	13	8	22	18		
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm							
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm							
※ 備考	運転管理に基づき 1号炉 10月1日立上げ 2号炉 10月11日立下げ 休炉																																