

# 施設排ガス測定データ

2022年 2月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	火	1	2	0	1	0	1	1	4	0	1	0	2	3	16	0	0	1	5	0.00	0.00	0.00	0.00	0.00	0.00	36	34	15	8	24	18
2	水	1	2	0	1	0	1	1	4	0	0	0	2	13	9	0	0	3	5	0.00	0.00	0.00	0.00	0.00	0.00	34	31	17	7	23	18
3	木	1	2	0	1	0	1	1	6	0	0	1	3	28	20	0	0	9	10	0.00	0.00	0.00	0.00	0.00	0.00	30	29	17	8	23	16
4	金	1	2	0	1	0	1	2	6	0	1	1	3	21	21	0	3	7	12	0.00	0.00	0.00	0.00	0.00	0.00	35	27	16	7	22	18
5	土	1	1	0	1	0	1	1	7	0	3	1	5	13	30	0	12	4	22	0.00	0.00	0.00	0.00	0.00	0.00	34	28	15	11	23	19
6	日	1	2	0	1	0	1	1	5	0	1	1	2	22	22	1	7	14	14	0.00	0.00	0.00	0.00	0.00	0.00	29	27	18	12	22	20
7	月	1	1	0	1	0	1	2	7	1	2	2	4	25	22	0	8	8	13	0.00	0.00	0.00	0.00	0.00	0.00	32	29	12	8	23	17
8	火	0	2	0	1	0	1	5	6	1	1	3	4	27	22	0	4	8	11	0.00	0.00	0.00	0.00	0.00	0.00	32	28	12	9	22	18
9	水	0	1	0	1	0	1	5	7	1	1	2	2	14	12	1	1	5	6	0.00	0.00	0.00	0.00	0.00	0.00	27	27	15	10	20	17
10	木	1	2	0	1	0	1	8	8	1	1	2	4	16	16	0	2	3	7	0.00	0.00	0.00	0.00	0.00	0.00	35	25	14	6	23	15
11	金	0	2	0	1	0	1	1	7	1	2	1	4	23	21	0	7	10	14	0.00	0.00	0.00	0.00	0.00	0.00	27	27	16	13	20	20
12	土	1	2	0	1	0	1	3	5	1	1	2	3	10	20	0	5	2	12	0.00	0.00	0.00	0.00	0.00	0.00	34	27	19	7	24	18
13	日	2	2	0	1	0	1	1	7	1	1	1	5	5	23	0	5	1	13	0.00	0.00	0.00	0.00	0.00	0.00	35	34	17	10	24	20
14	月	1	1	0	1	0	1	1	7	0	2	1	5	31	18	1	6	10	12	0.00	0.00	0.00	0.00	0.00	0.00	28	30	13	6	20	17
15	火	1	2	0	1	0	1	4	7	1	2	2	4	27	24	0	6	13	14	0.00	0.00	0.00	0.00	0.00	0.00	34	26	13	9	22	19
16	水	1	2	0	1	1	1	5	7	0	2	2	4	28	30	0	12	13	18	0.00	0.00	0.00	0.00	0.00	0.00	29	26	15	13	22	20
17	木	1	2	0	1	1	1	4	7	1	2	2	4	28	24	0	8	8	15	0.00	0.00	0.00	0.00	0.00	0.00	32	31	17	11	25	19
18	金	1	2	0	1	0	1	5	5	1	0	2	3	36	25	0	5	14	14	0.00	0.00	0.00	0.00	0.00	0.00	33	28	12	6	22	17
19	土	1	2	0	1	1	1	6	7	1	1	4	4	29	24	0	5	14	15	0.00	0.00	0.00	0.00	0.00	0.00	32	29	14	6	22	16
20	日	1	1	0	1	0	1	6	6	1	2	3	4	30	31	0	7	16	17	0.00	0.00	0.00	0.00	0.00	0.00	35	26	16	11	22	20
21	月	4	1	0	1	1	1	12	6	1	1	3	3	30	25	0	8	12	16	0.00	0.00	0.00	0.00	0.00	0.00	29	31	15	9	23	18
22	火	1	2	0	1	0	1	6	6	1	2	3	4	20	24	0	9	10	15	0.00	0.00	0.00	0.00	0.00	0.00	28	31	13	10	21	17
23	水	1	1	0	1	1	1	6	6	1	1	2	3	28	27	0	11	15	18	0.00	0.00	0.00	0.00	0.00	0.00	31	30	15	10	23	19
24	木	1	2	0	1	1	1	4	6	1	1	2	3	27	28	2	9	13	17	0.00	0.00	0.00	0.00	0.00	0.00	31	32	19	9	24	19
25	金	2	1	0	1	0	1	12	6	0	2	2	4	29	28	0	10	11	18	0.00	0.00	0.00	0.00	0.00	0.00	35	32	15	9	23	18
26	土	7	1	0	1	1	1	4	5	1	1	2	4	27	25	0	10	8	17	0.00	0.00	0.00	0.00	0.00	0.00	30	31	14	10	21	18
27	日	1	2	0	1	0	1	4	5	1	1	2	3	27	29	0	8	15	18	0.00	0.00	0.00	0.00	0.00	0.00	33	27	12	6	21	15
28	月	2	2	0	1	1	1	7	5	1	1	2	3	21	22	0	5	10	11	0.00	0.00	0.00	0.00	0.00	0.00	36	28	12	5	22	16
最大		7	2	0	1	1	1	12	8	1	3	4	5	36	31	2	12	16	22	0.00	0.00	0.00	0.00	0.00	0.00	36	34	19	13	25	20
最小		0	1	0	1	0	1	1	4	0	0	0	2	3	9	0	0	1	5	0.00	0.00	0.00	0.00	0.00	0.00	27	25	12	5	20	15
平均		1	2	0	1	0	1	4	6	1	1	2	4	23	23	0	6	9	14	0.00	0.00	0.00	0.00	0.00	0.00	32	29	15	9	22	18
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm					
法規制値		30 ppm						3,500 ppm 相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm					
※ 備考		休炉																													