

施設排ガス測定データ

2024年 1月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)									
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均					
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号				
1	月		2		1		1				6		2		4			19		3		13		0.00		0.00		0.00		38		26		34
2	火		2		1		1				8		4		6			28		9		16		0.00		0.00		0.00		37		31		34
3	水		1		1		1				5		2		4			22		6		14		0.00		0.00		0.00		36		29		34
4	木		2		1		1				6		2		4			25		6		15		0.00		0.00		0.00		36		31		34
5	金		1		1		1				6		3		4			24		9		16		0.00		0.00		0.00		36		31		34
6	土		1		1		1				7		2		5			28		8		17		0.00		0.00		0.00		37		31		34
7	日		1		1		1				7		2		5			30		9		21		0.00		0.00		0.00		36		32		35
8	月		2		1		1				7		3		5			30		13		20		0.00		0.00		0.00		36		32		34
9	火		2		1		1				7		2		5			27		9		20		0.00		0.00		0.00		36		29		34
10	水		3		1		2				6		1		4			29		5		16		0.00		0.00		0.00		38		27		34
11	木		2		1		1				7		3		5			25		10		18		0.00		0.00		0.00		37		29		34
12	金		2		1		1				7		2		5			26		9		18		0.00		0.00		0.00		37		32		34
13	土		2		1		1				7		3		5			30		8		22		0.00		0.00		0.00		38		31		34
14	日		2		1		1				7		4		6			30		14		20		0.00		0.00		0.00		36		32		34
15	月		2		1		1				7		1		4			30		10		22		0.00		0.00		0.00		38		27		34
16	火		2		1		2				7		2		4			29		9		18		0.00		0.00		0.00		38		28		34
17	水	立上げ	2	立上げ	1	立上げ	1	立上げ	6	立上げ	3	立上げ	4	立上げ	29	立上げ	15	立上げ	21	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	36	立上げ	32	立上げ	34	
18	木	2	2	1	1	1	2	6	6	2	2	3	3	18	30	6	7	10	19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	40	36	8	30	32	33	
19	金	1	2	1	1	1	2	6	7	1	2	3	4	19	30	7	12	13	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	38	37	27	28	34	34	
20	土	1	2	1	1	1	2	5	5	1	1	2	4	20	24	3	8	9	15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	36	29	32	34	34	
21	日	1	2	1	2	1	2	4	6	1	2	3	4	17	32	4	11	9	18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	36	36	25	28	33	33	
22	月	1	2	1	1	1	2	3	6	0	2	1	4	13	27	3	12	8	19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	36	27	24	33	32	
23	火	1	2	1	1	1	1	6	6	1	3	3	5	23	24	6	11	11	19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	36	28	30	32	34	
24	水	1	2	1	1	1	1	5	7	1	1	2	5	26	29	8	7	14	19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	36	30	31	35	34	
25	木	1	2	1	1	1	1	3	5	1	2	2	4	26	29	5	10	13	19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	36	22	31	33	34	
26	金	1	1	0	1	0	1	5	6	2	3	3	5	26	30	9	13	15	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	37	28	31	34	34	
27	土	1	2	0	1	0	1	5	7	2	1	4	4	24	26	9	6	16	20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	36	31	33	35	35	
28	日	1	2	0	1	0	1	4	5	1	1	2	3	22	26	4	7	10	16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	36	30	33	34	34	
29	月	1	2	0	1	0	1	5	6	2	2	3	4	20	28	6	10	11	19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	37	32	30	34	34	
30	火	1	2	0	1	0	1	6	5	2	2	4	4	22	28	6	9	14	18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	37	30	30	34	34	
31	水	1	2	0	1	1	2	7	5	1	1	2	3	18	27	5	9	11	18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	36	33	26	35	33	
最大		2	3	1	2	1	2	7	8	2	4	4	6	26	32	9	15	16	22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	40	38	33	33	35	35	
最小		1	1	0	1	0	1	3	5	0	1	1	3	13	19	3	3	8	13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	36	36	8	24	32	32	
平均		1	2	1	1	1	1	5	6	1	2	3	4	21	27	6	9	12	18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	37	27	30	34	34	
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm								
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.08 g/m ³ N						250 ppm								
※ 備考	運転管理に基づき 1号炉 1月17日立上げ 休炉																																	