

# 施設排ガス測定データ

2023年 6月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	木	1	2	1	1	1	2	6	6	2	1	4	3	31	28	7	10	17	18	0.00	0.00	0.00	0.00	0.00	0.00	33	35	22	24	29	31
2	金	1	2	0	2	1	2	7	5	2	2	4	3	24	27	10	13	16	19	0.00	0.00	0.00	0.00	0.00	0.00	33	36	24	31	29	33
3	土	1	2	0	1	1	2	6	5	1	1	3	2	31	29	8	7	19	18	0.00	0.00	0.00	0.00	0.00	0.00	33	36	26	22	29	32
4	日	1	2	0	1	1	1	6	6	2	1	4	3	30	31	20	18	25	26	0.00	0.00	0.00	0.00	0.00	0.00	34	36	25	29	29	34
5	月	1	2	0	1	1	2	7	8	1	1	3	3	30	29	9	13	22	20	0.00	0.00	0.00	0.00	0.00	0.00	32	37	20	29	27	33
6	火	1	2	0	1	1	2	7	6	2	1	4	2	30	26	6	6	16	16	0.00	0.00	0.00	0.00	0.00	0.00	31	37	21	28	28	33
7	水	1	2	0	1	1	1	6	5	2	1	4	2	24	30	7	8	13	14	0.00	0.00	0.00	0.00	0.00	0.00	32	36	23	27	28	33
8	木	1	2	0	1	1	2	6	7	2	1	4	3	27	30	10	11	16	17	0.00	0.00	0.00	0.00	0.00	0.00	32	36	24	30	29	34
9	金	1	2	0	1	1	2	6	5	1	1	3	2	27	28	4	5	14	14	0.00	0.00	0.00	0.00	0.00	0.00	33	35	20	23	27	32
10	土	1	2	0	1	1	2	7	6	3	1	5	4	24	27	11	5	18	16	0.00	0.00	0.00	0.00	0.00	0.00	32	36	24	20	29	31
11	日	1	2	0	1	0	2	6	6	2	1	4	3	27	28	10	8	19	17	0.00	0.00	0.00	0.00	0.00	0.00	32	35	24	20	29	32
12	月	1	2	0	1	1	2	7	5	2	1	5	3	28	30	7	7	19	17	0.00	0.00	0.00	0.00	0.00	0.00	33	36	23	25	28	32
13	火		2		2		2		4		1		2		22		8		14		0.00		0.00		0.00		37		27		33
14	水																														
15	木																														
16	金																														
17	土																														
18	日																														
19	月																														
20	火																														
21	水																														
22	木																														
23	金																														
24	土																														
25	日																														
26	月																														
27	火																														
28	水																														
29	木																														
30	金																														
最大		1	2	1	2	1	2	7	8	3	2	5	4	31	31	20	18	25	26	0.00	0.00	0.00	0.00	0.00	0.00	34	37	26	31	29	34
最小		1	2	0	1	0	1	6	4	1	1	3	2	24	22	4	5	13	14	0.00	0.00	0.00	0.00	0.00	0.00	31	35	20	20	27	31
平均		1	2	0	1	1	2	6	6	2	1	4	3	28	28	9	9	18	17	0.00	0.00	0.00	0.00	0.00	0.00	33	36	23	26	28	33
自主規制値		30				ppm		20				ppm		50				ppm		0.01				g/m <sup>3</sup> N		50				ppm	
法規制値		30				ppm		3,500				ppm 相当		430				ppm		0.04				g/m <sup>3</sup> N		250				ppm	
※ 備考	運転管理に基づき		1号炉		6月12日立下げ		2号炉		6月13日立下げ																		休炉				