

# 施設排ガス測定データ

2023年 12月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)							
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均			
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号		
1	金	4		1		1		7		1		4		32		12		19		0.00		0.00		0.00		36		31		34		
2	土	1		1		1		6		2		4		31		11		23		0.00		0.00		0.00		37		31		35		
3	日	1		1		1		6		2		5		30		13		21		0.00		0.00		0.00		37		29		34		
4	月	1		0		1		6		2		3		25		7		15		0.00		0.00		0.00		37		30		34		
5	火	1		1		1		9		1		4		31		10		23		0.00		0.00		0.00		38		29		33		
6	水	1		1		1		7		2		5		28		9		21		0.00		0.00		0.00		36		32		34		
7	木	1		1		1		6		3		4		27		14		22		0.00		0.00		0.00		38		30		34		
8	金	2		1		1		5		2		4		29		12		22		0.00		0.00		0.00		36		27		34		
9	土	5		1		1		9		2		5		33		19		25		0.00		0.00		0.00		36		32		34		
10	日	1		1		1		7		3		5		34		22		28		0.00		0.00		0.00		36		33		35		
11	月	1		0		1		6		3		4		31		6		20		0.00		0.00		0.00		37		31		35		
12	火	1		0		1		8		4		6		25		13		19		0.00		0.00		0.00		38		28		34		
13	水	1		0		1		7		4		5		30		16		23		0.00		0.00		0.00		37		30		34		
14	木	1		0		1		5		2		4		32		18		26		0.00		0.00		0.00		37		29		34		
15	金	1		1		1		5		2		4		30		12		24		0.00		0.00		0.00		37		29		34		
16	土	2		1		1		5		2		4		31		15		25		0.00		0.00		0.00		36		32		35		
17	日	2		1		1		6		2		3		30		17		25		0.00		0.00		0.00		36		25		34		
18	月	2		1		2		6		3		5		32		20		27		0.00		0.00		0.00		37		30		34		
19	火	2		1		1		6		1		3		30		12		23		0.00		0.00		0.00		37		30		34		
20	水	2	立上げ	1	立上げ	1	立上げ	5	立上げ	1	立上げ	2	立上げ	31	立上げ	7	立上げ	23	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	37	立上げ	23	立上げ	34	立上げ	
21	木	2	5	1	1	1	2	5	4	2	1	3	2	30	10	16	0	24	3	0.00	0.00	0.00	0.00	0.00	0.00	36	36	27	10	33	30	
22	金	2	2	1	1	1	1	5	7	1	1	3	4	34	19	22	6	27	11	0.00	0.00	0.00	0.00	0.00	0.00	38	36	29	28	34	33	
23	土	2	1	1	1	1	1	4	5	0	1	2	3	28	13	9	3	21	8	0.00	0.00	0.00	0.00	0.00	0.00	36	36	28	27	34	33	
24	日	2	1	1	1	1	1	6	7	2	3	4	5	34	15	19	7	28	11	0.00	0.00	0.00	0.00	0.00	0.00	36	36	30	30	34	34	
25	月	2	1	1	1	1	1	5	5	1	1	3	3	33	13	20	4	26	8	0.00	0.00	0.00	0.00	0.00	0.00	37	36	27	32	34	34	
26	火	2	1	1	1	1	1	4	5	1	1	3	3	34	18	12	5	25	8	0.00	0.00	0.00	0.00	0.00	0.00	37	37	17	33	34	35	
27	水	1	1	1	1	1	1	5	7	2	2	3	4	33	19	21	6	29	12	0.00	0.00	0.00	0.00	0.00	0.00	37	36	24	24	33	32	
28	木	1	2	0	1	1	1	6	5	1	1	3	3	37	20	24	9	30	14	0.00	0.00	0.00	0.00	0.00	0.00	37	35	29	18	34	33	
29	金	1	2	0	1	1	1	6	6	2	1	3	3	31	17	19	4	26	11	0.00	0.00	0.00	0.00	0.00	0.00	37	36	27	29	34	34	
30	土	立下げ	2	立下げ	1	立下げ	1	立下げ	7	立下げ	2	立下げ	5	立下げ	19	立下げ	7	立下げ	12	立下げ	0.00	立下げ	0.00	立下げ	0.00	立下げ	37	立下げ	32	立下げ	35	
31	日		2		1		1		6		3		4		19		7		12		0.00		0.00		0.00		36		29		34	
最大		5	5	1	1	2	2	9	7	4	3	6	5	37	20	24	9	30	14	0.00	0.00	0.00	0.00	0.00	0.00	38	37	33	33	35	35	
最小		1	1	0	1	1	1	4	4	0	1	2	2	25	10	6	0	15	3	0.00	0.00	0.00	0.00	0.00	0.00	36	35	17	10	33	30	
平均		2	2	1	1	1	1	6	6	2	2	4	4	31	17	15	5	24	10	0.00	0.00	0.00	0.00	0.00	0.00	37	36	29	27	34	33	
自主規制値		30 ppm				20 ppm				50 ppm				0.01 g/m <sup>3</sup> N				50 ppm														
法規制値		30 ppm				3,500 ppm相当				430 ppm				0.08 g/m <sup>3</sup> N				250 ppm														
※ 備考	運転管理に基づき 2号炉 12月20日立上げ 1号炉 12月30日立下げ																															
	休炉																															