

施設排ガス測定データ

2022年 4月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	金	3		0		1		1		0		0		30		0		11		0.00		0.00		0.00		36		18		25	
2	土	2		0		1		0		0		0		30		0		13		0.00		0.00		0.00		38		21		26	
3	日	4		0		1		0		0		0		37		0		11		0.00		0.00		0.00		35		17		26	
4	月	3		0		1		4		0		1		32		0		11		0.00		0.00		0.00		32		21		27	
5	火	2		0		1		0		0		0		27		0		10		0.00		0.00		0.00		35		21		27	
6	水	3		0		1		0		0		0		27		0		6		0.00		0.00		0.00		36		17		27	
7	木	1		0		1		0		0		0		20		0		4		0.00		0.00		0.00		37		18		28	
8	金	1		0		1		0		0		0		22		0		6		0.00		0.00		0.00		41		19		27	
9	土	1		0		1		4		0		1		24		0		5		0.00		0.00		0.00		37		21		29	
10	日	1		0		1		1		0		0		26		0		7		0.00		0.00		0.00		37		22		29	
11	月	1	12	0	2	1	3	1	1	0	0	0	1	20	6	0	0	3	1	0.00	0.00	0.00	0.00	0.00	0.00	40	28	18	3	26	8
12	火	2	2	0	1	1	2	1	4	0	1	0	2	24	15	0	4	8	8	0.00	0.00	0.00	0.00	0.00	0.00	35	32	10	3	24	14
13	水	2	3	1	2	1	2	1	4	0	2	0	3	31	21	0	6	3	11	0.00	0.00	0.00	0.00	0.00	0.00	34	29	15	5	25	18
14	木	2	3	1	2	1	2	1	7	0	2	0	4	16	15	0	7	2	10	0.00	0.00	0.00	0.00	0.00	0.00	37	34	23	9	31	21
15	金	立下げ	3	立下げ	1	立下げ	1	立下げ	8	立下げ	1	立下げ	4	立下げ	31	立下げ	2	立下げ	14	立下げ	0.00	立下げ	0.00	立下げ	0.00	立下げ	30	立下げ	5	立下げ	19
16	土		1		1		1		8		1		5		28		2		17		0.00		0.00		0.00		32		7		21
17	日		2		1		1		7		1		3		26		7		14		0.00		0.00		0.00		31		7		17
18	月		1		1		1		7		1		4		26		8		15		0.00		0.00		0.00		32		8		18
19	火		3		1		2		7		1		4		29		3		17		0.00		0.00		0.00		34		10		20
20	水		3		1		2		7		1		5		23		6		16		0.00		0.00		0.00		27		7		17
21	木		3		1		2		6		2		4		26		8		12		0.00		0.00		0.00		31		13		20
22	金		3		1		2		7		2		4		29		9		16		0.00		0.00		0.00		30		8		21
23	土		2		1		2		7		3		5		25		9		15		0.00		0.00		0.00		28		7		20
24	日		2		1		2		7		3		5		25		10		15		0.00		0.00		0.00		29		13		23
25	月		2		1		2		7		2		5		24		7		15		0.00		0.00		0.00		35		9		22
26	火		3		1		2		8		3		5		24		8		13		0.00		0.00		0.00		27		13		22
27	水		3		1		2		9		2		4		19		6		11		0.00		0.00		0.00		29		12		21
28	木		3		1		2		6		1		4		25		1		15		0.00		0.00		0.00		29		10		19
29	金		2		1		2		6		2		5		28		9		17		0.00		0.00		0.00		28		9		20
30	土		3		1		2		7		1		4		21		7		14		0.00		0.00		0.00		27		15		21
最大		4	12	1	2	1	3	4	9	0	3	1	5	37	31	0	10	13	17	0.00	0.00	0.00	0.00	0.00	0.00	41	35	23	15	31	23
最小		1	1	0	1	1	1	0	1	0	0	0	1	16	6	0	0	2	1	0.00	0.00	0.00	0.00	0.00	0.00	32	27	10	3	24	8
平均		2	3	0	1	1	2	1	7	0	2	0	4	26	23	0	6	7	13	0.00	0.00	0.00	0.00	0.00	0.00	36	30	19	9	27	19
自主規制値		30				ppm		20				ppm		50				ppm		0.01				g/m ³ N		50				ppm	
法規制値		30				ppm		3,500				ppm 相当		430				ppm		0.04				g/m ³ N		250				ppm	
※ 備考	運転管理に基づき		2号炉		4月11日立上げ		1号炉		4月15日立下げ																		休炉				