

# 施設排ガス測定データ

2019年 12月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)									
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均					
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号				
1	日		6		1		1				7		1		3			28		6		17		0.00		0.00		0.00		31		11		21
2	月		2		1		1				7		2		4			26		9		21		0.00		0.00		0.00		33		3		22
3	火		1		1		1				6		0		4			28		6		19		0.00		0.00		0.00		32		4		20
4	水	立上げ	2	立上げ	1	立上げ	1	立上げ	8	立上げ	1	立上げ	4	立上げ	4	立上げ	29	立上げ	6	立上げ	21	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	35	立上げ	6	立上げ	22	
5	木	1	2	1	1	1	1	5	4	1	1	3	3	14	29	5	7	11	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	36	29	11	13	22	21	
6	金	1	2	0	1	1	2	7	8	1	1	4	4	23	27	5	6	15	19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39	31	12	5	26	19	
7	土	2	2	0	1	1	1	6	5	2	1	4	4	23	27	6	6	16	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	38	29	10	10	26	19	
8	日	1	2	0	1	1	1	7	7	1	2	3	4	25	30	3	13	15	22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39	29	10	13	26	21	
9	月	1	1	0	1	1	1	7	6	3	2	5	4	29	30	10	14	18	23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	38	29	13	10	27	19	
10	火	1	1	0	0	0	1	7	6	2	3	4	4	22	29	7	19	15	25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39	30	10	8	22	19	
11	水	1	1	0	0	1	1	5	5	1	2	3	4	26	30	8	15	15	22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	36	29	9	15	26	22	
12	木	1	1	0	1	1	1	7	6	1	1	5	5	27	30	2	6	17	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	38	28	8	8	24	17	
13	金	6	2	0	1	1	2	8	7	1	2	5	5	24	26	3	13	13	22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	38	31	8	13	22	22	
14	土		3		2		2		6		1		4			26		8		20			0.00		0.00		0.00		32		4		21	
15	日		2		2		2		7		4		5			27		14		20			0.00		0.00		0.00		39		5		20	
16	月		3		2		2		7		1		4			27		10		18			0.00		0.00		0.00		34		12		22	
17	火		8		2		2		5		2		3			22		12		16			0.00		0.00		0.00		29		8		22	
18	水		3		2		2		7		2		5			29		14		23			0.00		0.00		0.00		32		15		24	
19	木		2		2		2		8		2		4			27		14		21			0.00		0.00		0.00		32		5		18	
20	金		3		2		2		7		3		4			30		12		23			0.00		0.00		0.00		35		5		15	
21	土		3		2		2		6		2		4			30		10		24			0.00		0.00		0.00		31		16		24	
22	日		2		2		2		6		2		4			30		11		22			0.00		0.00		0.00		29		5		22	
23	月		3		2		2		6		1		4			26		8		16			0.00		0.00		0.00		28		6		14	
24	火		3		2		2		7		2		5			27		12		21			0.00		0.00		0.00		30		10		21	
25	水		3		2		2		6		2		4			26		8		15			0.00		0.00		0.00		35		16		24	
26	木	5	3	1	2	2	2	5	7	1	1	2	4	3	26	0	3	1	14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	32	31	10	7	17	20	
27	金	2	3	1	2	1	3	7	8	1	1	4	4	21	32	1	4	10	19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	36	32	14	13	26	22	
28	土	1	3	1	2	1	2	8	6	2	2	5	5	26	30	12	16	18	25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	36	30	11	13	26	23	
29	日	1	3	1	2	1	2	7	7	2	1	5	4	28	29	12	7	23	23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39	32	12	3	25	18	
30	月	3	3	1	1	1	2	8	7	3	2	5	5	29	29	10	11	23	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	38	27	9	4	27	13	
31	火	1		1		1		7		3		5		28		13		21		0.00		0.00		0.00		0.00		37		10		24		
最大		6	8	1	2	2	3	8	8	3	4	5	5	29	32	13	19	23	25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39	39	14	16	27	24	
最小		1	1	0	0	0	1	5	4	1	0	2	3	3	22	0	3	1	14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	32	27	8	3	17	13	
平均		2	3	0	1	1	2	7	7	2	2	4	4	23	28	6	10	15	21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	37	31	10	9	24	20	
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm								
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm								
※ 備考		運転管理に基づき		1号炉	12月13日立下げ		1号炉	12月26日立上げ		2号炉	12月30日立下げ								休炉															
		設備保全に伴い		1号炉	12月4日立上げ		2号炉	12月23日立下げ・立上げ																										