

# 施設排ガス測定データ

2023年		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)					
5月		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号		
1	月	2	2	1	1	1	1	6	7	1	2	4	5	32	29	6	9	22	20	0.00	0.00	0.00	0.00	0.00	0.00	37	36	25	31	33	34
2	火	1	2	0	1	1	1	8	7	2	4	6	6	28	28	11	13	19	20	0.00	0.00	0.00	0.00	0.00	0.00	39	36	28	28	34	34
3	水	1	2	0	1	1	1	7	7	3	4	6	6	30	30	11	16	23	22	0.00	0.00	0.00	0.00	0.00	0.00	36	38	29	25	34	34
4	木	1	2	1	1	1	1	7	7	3	3	5	5	26	31	15	13	20	21	0.00	0.00	0.00	0.00	0.00	0.00	39	38	26	32	34	34
5	金	2	2	1	1	1	1	7	7	4	4	6	6	29	30	14	16	21	21	0.00	0.00	0.00	0.00	0.00	0.00	38	37	28	31	34	35
6	土	1	2	1	1	1	1	7	7	3	4	6	6	32	25	10	13	19	20	0.00	0.00	0.00	0.00	0.00	0.00	36	37	32	29	35	34
7	日	1	2	1	1	1	1	7	7	3	2	6	6	31	30	10	13	20	24	0.00	0.00	0.00	0.00	0.00	0.00	37	36	32	33	35	35
8	月	1	2	1	1	1	1	7	7	4	3	6	6	29	30	12	14	22	22	0.00	0.00	0.00	0.00	0.00	0.00	38	37	19	26	33	34
9	火	1	4	1	1	1	2	7	7	5	5	6	6	33	32	17	16	24	23	0.00	0.00	0.00	0.00	0.00	0.00	38	37	30	32	34	35
10	水	7	2	1	1	1	2	7	7	1	1	5	5	31	32	10	11	23	24	0.00	0.00	0.00	0.00	0.00	0.00	38	36	23	30	32	34
11	木	1	2	1	1	1	2	8	7	4	5	6	6	28	30	11	12	20	18	0.00	0.00	0.00	0.00	0.00	0.00	33	36	24	30	29	34
12	金	1	2	1	1	1	1	7	8	2	2	6	6	32	27	9	8	24	19	0.00	0.00	0.00	0.00	0.00	0.00	33	37	26	30	30	35
13	土	2	2	1	1	1	1	7	8	4	4	7	6	32	29	14	12	24	21	0.00	0.00	0.00	0.00	0.00	0.00	33	36	26	31	30	34
14	日	2	2	1	1	1	2	8	7	3	4	6	6	27	29	12	10	23	18	0.00	0.00	0.00	0.00	0.00	0.00	36	36	26	30	30	34
15	月	1	2	1	1	1	2	8	9	4	3	6	5	32	27	13	11	27	20	0.00	0.00	0.00	0.00	0.00	0.00	33	36	22	29	29	34
16	火	1	2	1	1	1	2	9	7	3	3	5	5	32	28	18	10	26	21	0.00	0.00	0.00	0.00	0.00	0.00	31	37	21	9	27	30
17	水	1	2	1	2	1	2	8	8	4	4	6	7	32	33	16	20	26	25	0.00	0.00	0.00	0.00	0.00	0.00	32	37	21	32	28	35
18	木	1	2	1	1	1	2	7	6	4	3	5	5	33	31	19	8	28	18	0.00	0.00	0.00	0.00	0.00	0.00	32	37	23	30	30	34
19	金	1	2	1	1	1	1	8	6	2	2	4	5	34	28	15	10	27	19	0.00	0.00	0.00	0.00	0.00	0.00	32	38	24	29	29	34
20	土	1	2	1	1	1	2	7	7	3	2	5	5	33	24	20	10	27	19	0.00	0.00	0.00	0.00	0.00	0.00	34	36	25	27	30	34
21	日	1	2	1	1	1	2	6	7	2	2	5	5	32	29	16	6	27	18	0.00	0.00	0.00	0.00	0.00	0.00	37	36	25	32	31	35
22	月	1	2	1	1	1	2	6	5	2	2	4	3	30	22	10	7	22	14	0.00	0.00	0.00	0.00	0.00	0.00	34	36	22	28	28	33
23	火	1	2	1	1	1	2	5	5	1	1	3	3	27	17	6	4	14	8	0.00	0.00	0.00	0.00	0.00	0.00	33	36	22	23	28	33
24	水	2	2	1	1	1	1	3	4	0	1	2	2	18	19	4	3	9	7	0.00	0.00	0.00	0.00	0.00	0.00	33	36	25	29	29	34
25	木	2	2	1	1	1	2	6	6	1	1	2	2	21	25	7	5	14	10	0.00	0.00	0.00	0.00	0.00	0.00	33	37	26	31	30	34
26	金	2	2	1	1	1	2	15	4	2	2	4	3	25	16	9	4	17	11	0.00	0.00	0.00	0.00	0.00	0.00	33	36	24	30	29	34
27	土	2	2	1	1	1	2	8	7	3	3	6	6	31	27	15	10	23	18	0.00	0.00	0.00	0.00	0.00	0.00	32	37	23	29	29	34
28	日	1	2	1	1	1	2	7	6	2	2	4	3	30	27	13	8	21	16	0.00	0.00	0.00	0.00	0.00	0.00	33	37	23	30	29	34
29	月	2	2	1	2	1	2	7	7	1	2	4	4	31	26	7	9	20	16	0.00	0.00	0.00	0.00	0.00	0.00	33	36	22	23	28	33
30	火	2	2	1	1	1	2	6	6	1	2	4	4	21	27	7	10	15	17	0.00	0.00	0.00	0.00	0.00	0.00	33	37	19	28	29	34
31	水	2	2	1	1	1	2	6	5	1	1	3	3	23	26	6	7	16	16	0.00	0.00	0.00	0.00	0.00	0.00	33	37	18	27	28	34
最大		7	4	1	2	1	2	15	9	5	5	7	7	34	33	20	20	28	25	0.00	0.00	0.00	0.00	0.00	0.00	39	38	32	33	35	35
最小		1	2	0	1	1	1	3	4	0	1	2	2	18	16	4	3	9	7	0.00	0.00	0.00	0.00	0.00	0.00	31	36	18	9	27	30
平均		2	2	1	1	1	2	7	7	3	3	5	5	29	27	12	10	21	18	0.00	0.00	0.00	0.00	0.00	0.00	35	37	24	29	31	34
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm					
※ 備考		休炉																													