

# 施設排ガス測定データ

2023年 8月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	火	1	2	1	2	1	2	5	6	0	1	2	3	27	32	5	8	15	18	0.00	0.00	0.00	0.00	0.00	0.00	38	36	19	24	32	33
2	水	2	2	1	2	1	2	4	6	1	1	2	3	27	30	11	11	16	21	0.00	0.00	0.00	0.00	0.00	0.00	36	36	22	25	31	33
3	木	1	2	1	2	1	2	5	11	1	2	3	4	24	31	11	9	16	19	0.00	0.00	0.00	0.00	0.00	0.00	37	35	18	26	32	32
4	金	1	3	1	2	1	2	11	8	1	2	4	4	28	29	13	13	21	21	0.00	0.00	0.00	0.00	0.00	0.00	36	36	26	27	33	33
5	土	2	2	1	2	1	2	6	7	1	2	5	5	30	32	7	12	21	22	0.00	0.00	0.00	0.00	0.00	0.00	38	36	28	23	33	33
6	日	1	2	1	2	1	2	6	7	1	1	4	5	33	32	8	11	22	24	0.00	0.00	0.00	0.00	0.00	0.00	36	37	19	25	32	33
7	月	2	2	1	2	1	2	5	6	1	1	3	3	25	29	7	6	14	17	0.00	0.00	0.00	0.00	0.00	0.00	34	36	24	25	30	32
8	火	1	2	1	2	1	2	7	6	3	3	4	4	22	26	10	11	15	18	0.00	0.00	0.00	0.00	0.00	0.00	39	36	27	29	33	33
9	水	2	2	1	2	1	2	7	9	1	4	5	5	24	26	6	12	18	18	0.00	0.00	0.00	0.00	0.00	0.00	36	36	23	22	30	32
10	木	2	2	1	2	1	2	8	11	1	2	5	5	28	29	8	7	18	17	0.00	0.00	0.00	0.00	0.00	0.00	37	36	21	23	30	32
11	金	2	2	1	2	1	2	7	7	3	5	5	6	31	30	13	16	22	22	0.00	0.00	0.00	0.00	0.00	0.00	36	36	28	30	33	34
12	土	2	2	1	2	1	2	6	6	1	2	4	5	30	29	10	9	21	21	0.00	0.00	0.00	0.00	0.00	0.00	38	36	26	27	32	34
13	日	2	6	1	1	1	2	6	7	1	2	3	5	30	30	11	10	19	20	0.00	0.00	0.00	0.00	0.00	0.00	37	37	31	31	34	34
14	月	2	2	1	1	1	2	7	8	2	4	5	6	26	29	14	16	20	23	0.00	0.00	0.00	0.00	0.00	0.00	36	36	18	30	32	34
15	火	1	2	1	1	1	2	7	9	2	3	5	5	32	32	12	18	21	25	0.00	0.00	0.00	0.00	0.00	0.00	36	37	31	28	34	33
16	水	1	2	1	1	1	2	7	7	2	2	5	5	29	29	15	9	22	22	0.00	0.00	0.00	0.00	0.00	0.00	35	35	21	23	29	32
17	木	1	2	1	1	1	2	7	7	3	4	5	6	32	32	20	19	26	25	0.00	0.00	0.00	0.00	0.00	0.00	36	35	25	23	32	31
18	金	1	2	1	2	1	2	7	7	2	2	4	4	32	35	17	14	26	25	0.00	0.00	0.00	0.00	0.00	0.00	37	37	27	22	32	33
19	土	1	9	1	2	1	2	5	8	2	2	3	4	32	33	13	12	26	24	0.00	0.00	0.00	0.00	0.00	0.00	37	36	20	31	32	34
20	日	1	2	1	2	1	2	6	7	1	2	4	4	30	32	10	10	22	26	0.00	0.00	0.00	0.00	0.00	0.00	37	37	29	24	33	34
21	月	2	2	1	1	1	2	6	7	1	2	3	4	32	32	10	15	22	24	0.00	0.00	0.00	0.00	0.00	0.00	36	37	23	28	32	33
22	火	2	2	1	2	1	2	6	6	1	1	3	4	31	32	6	7	17	20	0.00	0.00	0.00	0.00	0.00	0.00	37	37	21	27	33	33
23	水	1	2	1	2	1	2	5	6	1	1	3	4	18	20	7	6	13	13	0.00	0.00	0.00	0.00	0.00	0.00	36	35	25	27	31	33
24	木	1	2	1	2	1	2	6	6	1	1	3	3	25	26	6	6	14	15	0.00	0.00	0.00	0.00	0.00	0.00	37	37	25	32	33	34
25	金	1	2	1	2	1	2	4	5	1	1	2	2	17	27	6	7	12	14	0.00	0.00	0.00	0.00	0.00	0.00	38	36	20	27	31	33
26	土	1	2	1	2	1	2	5	5	1	2	3	4	32	32	12	11	21	21	0.00	0.00	0.00	0.00	0.00	0.00	35	38	25	29	32	34
27	日	1	2	1	2	1	2	7	6	1	3	4	4	30	31	11	16	21	25	0.00	0.00	0.00	0.00	0.00	0.00	37	37	28	28	33	34
28	月	2	2	1	2	1	2	5	5	2	2	4	4	31	32	8	15	18	23	0.00	0.00	0.00	0.00	0.00	0.00	36	36	22	23	31	33
29	火	2	3	1	2	1	2	6	6	2	2	4	4	26	30	11	11	18	22	0.00	0.00	0.00	0.00	0.00	0.00	36	42	26	21	33	32
30	水	1	2	1	2	1	2	7	7	2	2	4	4	28	30	11	11	18	23	0.00	0.00	0.00	0.00	0.00	0.00	36	36	27	29	32	34
31	木	1	2	1	2	1	2	7	5	1	2	3	4	28	27	8	10	16	20	0.00	0.00	0.00	0.00	0.00	0.00	38	36	26	20	32	33
最大		2	9	1	2	1	2	11	11	3	5	5	6	33	35	20	19	26	26	0.00	0.00	0.00	0.00	0.00	0.00	39	42	31	32	34	34
最小		1	2	1	1	1	2	4	5	0	1	2	2	17	20	5	6	12	13	0.00	0.00	0.00	0.00	0.00	0.00	34	35	18	20	29	31
平均		1	2	1	2	1	2	6	7	1	2	4	4	28	30	10	11	19	21	0.00	0.00	0.00	0.00	0.00	0.00	37	36	24	26	32	33
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm					
法規値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm					
※ 備考		■■■■ 休炉																													