

施設排ガス測定データ

2024年 9月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	日	1	1	0	0	0	0	4	5	2	3	3	4	31	28	18	12	24	19	0.00	0.00	0.00	0.00	0.00	0.00	37	36	31	29	35	34
2	月	1	1	0	0	1	1	4	4	1	0	2	2	30	21	10	4	22	11	0.00	0.00	0.00	0.00	0.00	0.00	36	36	19	23	31	32
3	火	1	1	0	0	1	1	4	6	1	0	3	2	30	21	9	2	21	10	0.00	0.00	0.00	0.00	0.00	0.00	36	36	27	19	31	31
4	水	1	1	0	0	0	0	5	4	0	0	2	2	29	15	11	5	22	10	0.00	0.00	0.00	0.00	0.00	0.00	36	36	25	28	33	33
5	木	1	1	0	0	0	0	9	4	0	1	2	3	31	29	14	9	25	17	0.00	0.00	0.00	0.00	0.00	0.00	37	37	25	32	33	34
6	金	0	1	0	0	0	0	5	7	2	1	3	3	32	26	18	12	27	18	0.00	0.00	0.00	0.00	0.00	0.00	36	37	28	20	33	31
7	土	1	1	0	0	0	0	4	6	2	2	2	3	31	33	17	10	24	20	0.00	0.00	0.00	0.00	0.00	0.00	36	36	22	25	32	32
8	日	1	1	0	0	0	0	3	5	1	1	2	3	31	29	17	10	25	20	0.00	0.00	0.00	0.00	0.00	0.00	36	36	30	30	34	34
9	月	1	1	0	0	0	0	4	5	1	1	3	3	30	30	13	8	23	18	0.00	0.00	0.00	0.00	0.00	0.00	36	38	30	26	34	32
10	火	1	1	0	0	0	0	6	7	2	2	3	4	29	29	15	11	24	18	0.00	0.00	0.00	0.00	0.00	0.00	35	37	29	21	33	32
11	水	1	1	0	0	0	0	6	9	1	1	3	3	35	29	15	7	23	14	0.00	0.00	0.00	0.00	0.00	0.00	36	36	27	23	31	30
12	木	1	1	0	0	0	0	5	7	2	3	4	5	32	27	26	13	29	22	0.00	0.00	0.00	0.00	0.00	0.00	37	37	28	18	33	32
13	金	1	4	0	0	0	0	4	6	1	1	3	3	33	29	16	9	26	19	0.00	0.00	0.00	0.00	0.00	0.00	37	36	23	21	32	32
14	土	1	1	0	0	0	0	3	5	1	1	2	2	31	28	10	9	23	18	0.00	0.00	0.00	0.00	0.00	0.00	36	36	23	23	32	33
15	日	1	1	0	0	0	0	4	5	2	1	3	3	32	31	21	11	27	21	0.00	0.00	0.00	0.00	0.00	0.00	37	37	26	25	33	34
16	月	1	1	0	0	0	0	4	4	1	0	3	2	31	23	19	6	26	15	0.00	0.00	0.00	0.00	0.00	0.00	36	36	29	26	33	32
17	火	1	1	0	0	0	0	3	3	0	1	2	1	33	23	11	3	23	13	0.00	0.00	0.00	0.00	0.00	0.00	36	36	25	22	31	30
18	水	2	1	0	0	0	0	5	4	2	1	3	2	33	18	20	3	26	10	0.00	0.00	0.00	0.00	0.00	0.00	36	36	30	24	33	32
19	木	1	1	0	0	0	0	4	4	1	0	2	2	31	19	14	2	25	11	0.00	0.00	0.00	0.00	0.00	0.00	36	37	22	21	31	29
20	金	1	7	0	0	0	0	3	7	1	0	2	2	30	25	10	2	24	13	0.00	0.00	0.00	0.00	0.00	0.00	36	37	25	26	32	32
21	土	1	1	0	0	0	0	3	6	1	2	2	3	32	28	17	9	25	17	0.00	0.00	0.00	0.00	0.00	0.00	36	38	27	27	33	34
22	日	0	0	0	0	0	0	5	6	2	2	3	4	34	28	23	8	29	19	0.00	0.00	0.00	0.00	0.00	0.00	37	37	28	24	34	32
23	月	0	0	0	0	0	0	4	5	0	0	2	2	34	28	16	8	27	18	0.00	0.00	0.00	0.00	0.00	0.00	36	37	22	22	31	30
24	火	0	0	0	0	0	0	6	6	1	1	3	4	33	30	17	8	29	20	0.00	0.00	0.00	0.00	0.00	0.00	35	37	26	25	31	33
25	水	0	0	0	0	0	0	4	6	1	1	3	3	32	28	19	10	28	21	0.00	0.00	0.00	0.00	0.00	0.00	35	33	25	18	30	28
26	木	0	0	0	0	0	0	5	5	1	1	2	3	32	31	19	12	27	23	0.00	0.00	0.00	0.00	0.00	0.00	35	36	25	21	32	32
27	金	0	1	0	0	0	0	4	6	2	1	3	4	34	28	22	13	28	22	0.00	0.00	0.00	0.00	0.00	0.00	35	36	27	21	32	30
28	土	0		0		0		5		1		2		31		15		23		0.00		0.00		0.00		37		28		33	
29	日	0		0		0		5		0		3		32		5		25		0.00		0.00		0.00		36		26		34	
30	月	0		0		0		4		1		2		33		12		23		0.00		0.00		0.00		36		22		32	
最大		2	7	0	0	1	1	9	9	2	3	4	5	35	33	26	13	29	23	0.00	0.00	0.00	0.00	0.00	0.00	37	38	31	32	35	34
最小		0	0	0	0	0	0	3	3	0	0	2	1	29	15	5	2	21	10	0.00	0.00	0.00	0.00	0.00	0.00	35	33	19	18	30	28
平均		1	1	0	0	0	0	4	5	1	1	3	3	32	26	16	8	25	17	0.00	0.00	0.00	0.00	0.00	0.00	36	36	26	24	32	32
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.08 g/m ³ N						250 ppm					
※ 備考		運転管理に基づき 2号炉 9月27日立下げ 休炉																													